
RATINGS:



NOTES:

- DIMENSIONS IN MILLIMETRES (INCHES).
- 2. TERMINAL-BLOCK SCREWS: 6-32 x 0.25.
- 3. MOUNTING SCREWS: M4 OR 8-32.
- 4. ENCLOSURE IS ELECTRICALLY CONNECTED TO TERMINAL G THROUGH JUMPER FROM TERMINAL G TO ⊕ SCREW. THIS CONNECTION MAY BE REMOVED FOR DIELECTRIC STRENGTH TESTING. ENSURE THAT THE JUMPER IS INSTALLED AFTER TESTING.